

## ***E - Daycare Facility***

More than 6 children 2 years of age and older who receive educational, supervision, or personal care services, less than 24-hour care

### **Outside**

Address numbers visible from street.

Occupancy shall front directly on a public street or an exit discharge not less than 20 feet in width.

### **Miscellaneous**

Use of open flame shall not be permitted in Licensed Care Facilities.

### **Exits and Doors**

An approved fire safety and evacuation plan is required with evacuation drills held every 6 months.

Exit doors, including manually operated horizontal sliding doors, shall open from the inside without use of a key, special knowledge, or effort.

The unlatching of any door or leaf shall not require more than one operation.

Exits and stairwells are free of storage and combustible material.

Security bars are operable from the inside without key or special knowledge.

### **CO Detectors**

Carbon monoxide detection shall be provided in dwelling units, sleeping units, and classrooms that contain a fuel-burning appliance or fireplace.

### **Fire Alarms**

An automatic fire alarm system that activates the occupant notification system in accordance with CFC 907.5.

- Smoke detectors shall be installed in rooms used for napping or sleeping
- ***Exception:*** Automatic detection devices are not required where an approved fire sprinkler is installed. Manual activation shall be provided from a normally occupied location.

### **Automatic Sprinkler Systems**

An automatic sprinkler system shall be provided throughout buildings with day care facilities under Group I-4 occupancies and Group E occupancies.

### **Extinguishers**

Minimum 2A:10-B:C extinguisher provided and maintained annually by licensed technician.

Travel distance to any extinguisher is no more than 75 feet.

Mounted 3-5 ft. from floor with hangars or brackets supplied with extinguisher.

## **Water Heaters**

Properly secured and installed per manufacturer instructions.

Combustion chamber or heating element is guarded from accidental contact and adjacent area clear of combustibles.